WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38649
Permit No.
Basin 87

NOTICE OF INTENT NO. 18533

1. OWNER Micky Finn
MAILING ADDRESS 245 Vine St. #F
Reno, NV 89503

ADDRESS AT WELL LOCATION
10865 Dryden
Reno, NV 89509

2. LOCATION SE ¼ SW ¼ Sec. 12 T 18N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 40-712-20 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
We abandoned this well by first perforating the casing from 100' to top using a Mills Knife perforator. We then pumped neat cement from the bottom to the top using approximately 2 yards neat cement. Static water level before abandonment was 8' below surface. Total depth was 120'. We cut the casing off approximately 1½-2' below grade. A new well will be drilled as time permits. This well was abandoned due to its location in relation to his septic system and house which are being built at this time. The old well log shows factory perfs 100' to 120' done by Wayne Drilling.				

Date started 1-22, 1992
Date completed 1-23, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1719
Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)
Date Jan 23, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627