

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19637

1. OWNER SCOLARIS WAREHOUSE MARKETS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1836 10TH STREET _____
LOS ANGELES, CA 93402 _____
1901 SILVERLADA BLVD. _____
RENO, NV _____
 2. LOCATION NE 1/4 NW 1/4 Sec. 06 T. 19 N. R. 20 E. WASHOE County _____
 PERMIT NO. M/O-502 _____
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX

6. LITHOLOGIC LOG W-2 SEE SITE PLAN

Material	Water Strata	From	To	Thick-ness
ASPHALT CONCRETE	NO	0	4"	4"
AGGREGATE BASE	NO	4"	1.3'	1'
BROWN CLAYEY SAND	NO	1.3'	6'	4.7'
BROWN SAND	NO	6'	10'	4'
TAN SANDY CLAY	NO	10'	12'	2'
LIGHT BROWN SILTY GRAVEL	NO	12'	40'	28'
BROWN CLAYEY SAND to SANDY CLAY	NO	40'	42.5'	2.5'
GRAY to BROWN SILTY GRAVEL to SANDY GRAVEL (with boulders/cobbles)	NO	42.5'	52.5'	10'
BROWN CLAYEY SAND	NO	52.5'	55.2'	2.7'

NOTE: DRILLED TO 53.7', SAMPLED TO 55.2'

8. WELL CONSTRUCTION
 Depth Drilled 53.7 Feet Depth Cased 53.7 Feet
 HOLE DIAMETER (BIT SIZE)
 From 5 Inches To 53.7 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>SCHED. 40</u>	<u>0.25</u>	<u>53.7</u>

Perforations:
 Type perforation SLOTTED
 Size perforation 0.022"
 From 13.5 feet to 53.5 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 8.5 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured BENT. PLUG FROM 8.5-11.5' Concrete Grout
 Gravel Packed: Yes No #3 SAND
 From 11.5 feet to 53.7 feet

9. WATER LEVEL
 Static water level NOT ENCOUNTERED feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name [Signature]
 Address 1635 Bellford RD
RENO, NV, 89509
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 3/2/92

Date started 1-31, 1992
 Date completed 2-3, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

STATE ENGINEERS INC. MAR 24 AM 11:30 '92