



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10276

1. OWNER Sharon Mahlin ADDRESS AT WELL LOCATION 1630 East Guffy
 MAILING ADDRESS 985 Brenda Way 1630 East Guffy
Carson City, Nv 89704 Lot 2 Block E

2. LOCATION NE 1/4 NW 1/4 Sec. 30 T. 17 N/S R. 20 E. Washoe County
 PERMIT NO. 050-295-13 - New Washoe City
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden sand & decomposed granite		0	4	4
Decomposed granite tan		4	85	81
Hard granite black specs		85	92	7
Granite & D.G. mixed & black & yellow pyrite chips		92	120	28
More granite than D.G. & pyrite black & yellow		120	130	10
More D.G. than granite & pyrite		130	150	20
D.G. granite tan & reddish brown pyrite		150	199	49
T.D. 199 ft				

8. WELL CONSTRUCTION
 Depth Drilled 199 Feet Depth Cased 199 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10 5/8</u>	0	50	Feet
<u>8 1/2</u>	50	199	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>199</u>

Perforations:
 Type perforation factory - double
 Size perforation 3/32 X 3

From 159 feet to 179 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 199 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started 1/30/92, 19_____
 Date completed 1/31/92, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>		<u>1 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
 Contractor
Sparks, Nv 89431

Nevada contractor's license number issued by the State Contractor's Board 15291
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1804

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 2/10/92