

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO18834

1. OWNER LES JONES ADDRESS AT WELL LOCATION 280 Riverbend  
 MAILING ADDRESS 2910 Shavez Reno, NV 89523  
Reno, NV 89502

2. LOCATION NW 1/4 SW 1/4 Sec. 15 T. 19N N/S R. 18 E Washoe County  
 PERMIT NO. 38-655-03 Beli Ranch  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Black top soil		0	1	1
Brown clay with some gravels		1	14	13
Boulder & gravels not much clay		14	26	12
Coarse sands & gravels		26	31	5
Granite boulder		31	36	5
Boulder & granite		36	83	47
Granite boulder		83	89	6
Gravels & silthy sands		89	105	16
Rusty silthy clay		105	109	4
Soft sandy brown clays		109	129	20
Dark brown clay		129	132	3
Gray clay		132	146	14
Black clay		146	150	4
Soft zone		150	155	5
Gray & black clay		155	172	17
Soft zone	X	172	176	4
Gray clay		176	201	25
Soft zone	X	201	206	5
Sticky gray clay		206	235	29
Soft zone	X	235	240	5
Gray clay		240	250	10

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet 250 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	250

Perforations: factory sawed slot  
 Type perforation \_\_\_\_\_  
 Size perforation 3/32 x 3 x 5 around  
 From 145 feet to 165 feet  
 From 185 feet to 205 feet  
 From 225 feet to 245 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 100  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 250 feet

9. WATER LEVEL  
 Static water level 146 feet below land surface  
 Artesian flow 30 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality clear

Date started 1-30-92, 19  
 Date completed 2-3-92, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc.  
 Contractor  
 Address P.O. Box 12370, Reno, NV 89510  
 Contractor  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed Jerry C. Hedman  
 by driller performing actual drilling on site or contractor  
 Date February 5, 1992