WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38666
Permit No.
Basin 92A

I

NOTICE OF INTENT No. 18836

1. OWNER ROB & LINDA PIERCE
MAILING ADDRESS 3939 Clear Acre Lane #225
Reno, NV 89512

ADDRESS AT WELL LOCATION 11095 Cimarron
Reno, NV 89506

2. LOCATION NE ¼ SW ¼ Sec 24 T 21N N/S R 18 E Washoe County

PERMIT NO. (Issued by Water Resources) 86-205-12 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	36	35
BRown sandy clay		36	71	35
Brown clay		71	138	67
Soft zone	X	138	143	5
BRown clay		143	151	8
Soft zone	X	151	168	17
Brown clay		168	176	8
Soft zone	X	176	183	7
BRown clay		183	187	4

'92 JAN 27 P 2:39
STATE ENGINEER

Date started 1-16-92, 19
Date completed 1-16-92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 187 Feet Depth Cased 187 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	187	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	187

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 187 feet

9. WATER LEVEL
Static water level 121 feet below land surface
Artesian flow 30 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne DRilling, Inc.
Contractor

Address P.O. Box 12370, Reno, NV 89510
Contractor

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Gary C. Hedman
By driller performing actual drilling on site or contractor

Date January 21, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627