WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK 11ADB

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38677
Permit No.
Basin 93

NOTICE OF INTENT NO. 18837

1. OWNER CANDY BUTLER
MAILING ADDRESS 11795 Fir
Reno, NV 89506

ADDRESS AT WELL LOCATION 1055 Silverwood
Reno, NV 89506

2. LOCATION SE ¼ NE ¼ Sec. 11 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 79-500-~~26~~52 (Parcel No.) Antelope Valley 2nd Rock Estates #243 parcel 1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown clay with D.G.		2	36	34
Soft brown sand		36	41	5
Brown clay with D.G.		41	91	50
Dark brown sandy clay		91	106	15
Weathered green granite		106	199	93
Soft zone	X	199	205	6
Weathered granite		205	255	50
Soft zone	X	255	260	5
Weathered granite		260	275	15

RECEIVED '92 FEB 27 A11:04 STATE ENGINEERS OFFICE

Date started 2-17-92, 19
Date completed 2-19-92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	275	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	275

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 206 feet to 226 feet
From 246 feet to 266 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 275 feet

9. WATER LEVEL
Static water level 94 feet below land surface
Artesian flow 25 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, INc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2-24, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627