WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38672
Permit No.
Basin 99

NOTICE OF INTENT No 18832

1. OWNER RANDY OWEN
MAILING ADDRESS 3540 Meadow Lark Drive
Reno, NV 89506

ADDRESS AT WELL LOCATION
45 Quarter HOrse
Reno, NV 89506

2. LOCATION NE ¼ SE ¼ Sec. 8 T. 23N N/S R. 18 E. Washoe County

PERMIT NO. (Issued by Water Resources) | 078-172-09 (Parcel No.) | Rancho Haven (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow sand		0	9	9
Brown clay		9	10	1
Brown sandy clay		10	23	13
Brown clay		23	43	20
Weathered granite		43	70	27
Soft zone (NO WATER)		70	71	1
WEathered granite		71	171	100
Soft zone	X	171	173	2
Weathered granite		173	217	44
Soft zone	X	217	219	2
Weathered granite		219	227	8
Pink granite		227	235	8
FRactured granite	X	235	240	5
Pink granite		240	245	5

Date started 1-20-92, 19
Date completed 1-21-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 245 Feet Depth Cased 245 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	245 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	245

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 170 feet to 190 feet
From 210 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 245 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow 35+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date January 24, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627