WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

in Book

OFFICE USE ONLY
Log No. 38688
Permit No.
Basin 162

NOTICE OF INTENT NO. 11097

1. OWNER Kings Land Development ADDRESS AT WELL LOCATION Murphy
MAILING ADDRESS

2. LOCATION NE ¼ NW ¼ Sec. 13 T. 20s N/S R. 52 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) 28-702-15 (Parcel No.) Charleston Park Lot 33 Unit 2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	3'	3'
Caliche		3'	5'	2'
Clay		5'	19'	14'
Caliche		19'	21'	2'
Clay		21'	35'	14'
Caliche		35'	38'	3'
Clay		38'	62'	24'
Caliche	WB	62'	64'	2'
Clay		64'	74'	10'
Caliche	WB	74'	76'	2'
Clay		76'	90'	14'
Caliche	WB	90'	92'	2'
Clay		92'	114'	22'
Caliche	WB	114'	116'	2'
Clay		116'	122'	6'
Caliche	WB	122'	124'	2'
Clay		124'	135'	11'
Caliche	WB	135'	137'	2'
Clay		137'	140'	

RECEIVED
JUL 22 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 7-2, 1992
Date completed 7-6, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0'	140'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
Signed Steve Scearce (By driller performing actual drilling on site or contractor)
Date 7-17-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627