WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

In Book

OFFICE USE ONLY
Log No. 38689
Permit No.
Basin 162

NOTICE OF INTENT NO. 11098

1. OWNER Kings Land Development ADDRESS AT WELL LOCATION Basin St.
MAILING ADDRESS

2. LOCATION NE ¼ NW ¼ Sec. 13 T. 20S N/S R. 52 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) 28-701-14 (Parcel No.) Charleston Park Lot 1 Unit 2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	6'	6'
Caliche		6'	8'	2'
Clay		8'	16'	8'
Caliche		16'	18'	2'
Clay		18'	40'	22'
Caliche		40'	42'	2'
Clay		42'	59'	17'
Caliche	WB	59'	61'	2'
Clay		61'	72'	11'
Caliche	WB	72'	74'	2'
Clay		74'	83'	9'
Caliche	WB	83'	85'	2'
Clay		85'	115'	30'
Caliche	WB	115'	117'	2'
Clay		117'	123'	6'
Caliche	WB	123'	125'	2'
Clay		125'	130'	5'
Caliche	WB	130'	132'	2'
Clay		132'	138'	6'
Caliche	WB	138'	140'	2'

RECEIVED JUL 22 1992 Div. of Water Resources Branch Office - Las Vegas, NV

Date started 7-7, 1997
Date completed 7-7, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)
12¼ Inches From 0' Feet To 140' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Sawcut
Size perforation 18 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
Signed Steve Sceace (By driller performing actual drilling on site or contractor)
Date 7-7-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627