

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **11846**

1. OWNER **EUGENE MAYEA** ADDRESS AT WELL LOCATION **3291 PROSPECTOR**  
**PARRUMP, NEV 89041**  
 MAILING ADDRESS **3291 PROSPECTOR**  
**PARRUMP, NEV 89041**

2. LOCATION **NE 1/4 SE 1/4 Sec 13 T. 20 N/S R. 52 E** County **NYE**  
 PERMIT NO. **106** Parcel No. **CHAS. PK RANCHOS** Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material        | Water Strata | From | To  | Thick-ness |
|-----------------|--------------|------|-----|------------|
| Brown Clay      |              | 0    | 4   | 4          |
| Sticky Br. Clay |              | 4    | 7   | 3          |
| Light Br. Clay  |              | 7    | 12  | 11         |
| Soft limestone  |              | 12   | 32  | 14         |
| Coarse Gravel   | x            | 32   | 33  | 1          |
| Brown Clay      |              | 33   | 80  | 47         |
| Soft Clay       | x            | 80   | 84  | 4          |
| Firm Brown Clay |              | 84   | 110 | 26         |
| Sandy Clay      | x            | 110  | 112 | 2          |
| Lt. Brown Clay  |              | 112  | 125 | 13         |
| Sand            | x            | 125  | 128 | 3          |
| Soft Clay       |              | 128  | 145 | 17         |
| Hard Brown Clay |              | 145  | 160 | 15         |

8. WELL CONSTRUCTION  
 Depth Drilled **160** Feet Depth Cased **162** Feet

HOLE DIAMETER (BIT SIZE)  
 From **12** Inches To **160** Feet  
 From **0** Feet To **160** Feet  
 From **12** Inches To **0** Feet  
 From **0** Feet To **160** Feet  
 From **12** Inches To **0** Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <b>8 5/8</b>       | <b>18</b>           | <b>188</b>              | <b>0</b>    | <b>162</b> |

Perforations:  
 Type perforation **Factory**  
 Size perforation **1/2 x 3**  
 From **120** feet to **140** feet  
 From **120** feet to **140** feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal **62 ft**

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From **62** feet to **160** feet

9. WATER LEVEL  
 Static water level **40** feet below land surface  
 Artesian flow **0** G.P.M. **0** P.S.I.  
 Water temperature **Cold** °F Quality **Good**

Date started **8-20** 19**92**  
 Date completed **8/26** 19**92**

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

| G.P.M.    | Draw Down (Feet Below Static) | Time (Hours)  |
|-----------|-------------------------------|---------------|
| <b>30</b> | <b>10</b>                     | <b>40 Min</b> |

**RECEIVED**  
**AUG 27 1992**  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge

Name **O.M. Gullard Drilling** Contractor  
 Address **6022 So Euclid Ave** Contractor  
**Las Vegas, Nev 89120**

Nevada contractor's license number issued by the State Contractor's Board **4796**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **115**

Signed **O.M. Gullard**  
 By driller performing actual drilling on site or contractor

Date **8/27/92**