WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38709
Permit No.
Basin

NOTICE OF INTENT NO. 11117

1. OWNER Bob Weiss
MAILING ADDRESS
ADDRESS AT WELL LOCATION Landmark

2. LOCATION SE ¼ NE ¼ Sec. 6 T. 20S N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) | 36-027-14 (Parcel No.) | Landmark Lot 2 Blk D (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	10'	10'
Calichie		10'	12'	2'
Clay		12'	31'	19'
Calichie		31'	33'	2'
Clay		33'	44	11'
Calichie	WB	44'	46'	2'
Clay		46'	62'	16'
Calichie	WB	62'	64'	2'
Clay		64'	73'	9'
Calichie	WB	73'	75'	2'
Clay		75'	87'	12'
Calichie	WB	87'	89'	2'
Clay		89'	103'	14'
Calichie	WB	103'	105'	2'
Clay		105'	126	21'
Calichie	WB	126'	128'	2'
Clay		128'	137'	9'
Calichie	WB	137'	139'	2'
Clay		139'	140'	1'

RECEIVED
AUG 18 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8-7, 1992
Date completed 8-10, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0'	140'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
Signed Steve Scearce (By driller performing actual drilling on site or contractor)
Date 8-12-92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627