WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38727
Permit No.
Basin

NOTICE OF INTENT NO. 11133

1. OWNER Ken Gager
MAILING ADDRESS
ADDRESS AT WELL LOCATION Calvada Blvd

2. LOCATION SW ¼ NE ¼ Sec. 28 T. 20S N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) | 39-074-05 (Parcel No.) | Calvada Valley Unit 8B Lot 26 Blk 18 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	4'	4'
Calichie		4'	8'	4'
Clay		8'	22'	14'
Calichie		22'	24'	2'
Clay		24'	33'	9'
Calichie		33'	35'	2'
Clay		35'	50'	15'
Calichie	WB	50'	52'	2'
Clay		52'	61'	9'
Calichie	WB	61'	63'	2'
Clay		63'	72'	9'
Calichie	WB	72'	74'	2'
Clay		74'	83'	9'
Calichie	WB	83'	85'	2'
Clay		85'	115'	30'
Calichie	WB	115'	117'	2'
Clay		117'	129'	12'
Calichie	WB	129'	131'	2'
Clay		131'	137'	6'
Calichie	WB	137'	139'	2'
Clay		139'	140'	1'

Date started 8-8, 19 92
Date completed 8-14, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
AUG 21 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0' Feet	140' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
Signed Steve Scease (By driller performing actual drilling on site or contractor)
Date 8-17-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627