BW-25

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38776
Permit No.
Basin 54-061-Bandse

NOTICE OF INTENT NO. 17979

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ NW ¼ Sec. 24 T. ~~30~~ 36 N/~~S~~ R. 49 E. EUREKA County

PERMIT NO. 55142 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL W/CLAY		0	150	150
BLACK ROCK W/CLAYS		150	250	100
BLACK ROCK W/FRACTURES		250	1000	750
BLACK ROCK W/CLAYS		1000	1050	50
BLACK ROCK W/QUARTZ		1050	1300	250
BLACK ROCK W/CLAYS		1300	1450	150
BLACK ROCK W/FRACTURES		1450	1750	300
BLACK ROCK		1750	1800	50
BLACK ROCK-FRACTURED		1800	1900	100
BLACK ROCK W/CALCITE		1900	1970	70
BLACK ROCK W/WHITE QUARTZ		1970	2000	30
BLACK ROCK-FRACTURED		2000	2044	44

'92 AUG 18 A10:22
RECEIVED
STATE ENGINEERS OFFICE

Date started 07-14, 19 92
Date completed 08-05, 19 92

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 2044 Feet Depth Cased 2030 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
48	Inches	0	Feet	78	Feet
31	Inches	78	Feet	2044	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
40	159	.375	0	78
24	95	.375	0	310
24	95	.375	350	2030

Perforations:
Type perforation LOUVERED
Size perforation .125"X2"
From 310 feet to 350 feet
From 510 feet to 550 feet
From 870 feet to 910 feet
From 1230 feet to 1270 feet
From 1590 feet to 1990 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 2044 feet

9. WATER LEVEL
Static water level 540 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 125 °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING
Contractor
Address 2286 WEST 1500 SOUTH
Contractor
SALT LAKE CITY, UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1809

Signed Benjie Ktoflet
By driller performing actual drilling on site or contractor

Date 08-05-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627