

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19682

1. OWNER Groundwater Res. Consultants, Inc. ADDRESS AT WELL LOCATION Rocketdyne-Reno
 MAILING ADDRESS 1735 E. Ft. Lowell Rd. Ste. 4 2555 Whiskey Springs Road
Tucson, AZ 85719 Warm Springs Valley, Reno NV

2. LOCATION SW 1/4 SE 1/4 Sec. 12 T. 22N N/S R. 21 E Washoe County Washoe
 PERMIT NO. M/O 431B D-7A 77-110-01 Palomino Valley Unit 1 12-2-15
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clayey gravelly sand. Grey-brown, dry, well graded, angular loose, uncemented, abundant silt		0	12	12
At 7 feet decreasing gravel fraction.				
Clayey silty sand. Brown, slightly moist moderately graded, loose, uncemented.		12	15	3
No gravel				
Clayey sandy gravel. Red-brown, moderately moist, well graded, angular, loose, un-cemented.				
At 20 feet becomes very moist.				
At 22 feet cuttings are wet.				
At 28 feet hole produces water	X	15	44.5	29.5

8. WELL CONSTRUCTION
 Depth Drilled 44.5 Feet Depth Cased 44.5 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 5/16 Inches To 0 Feet 44.5 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

I.D. Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 40	0	44.5
4" PVC end cap centralizers at 19, 44				
4" PVC locking cap				

Perforations: factory sawed slot
 Type perforation.....
 Size perforation .020 x 3
 From 19.5 feet to 44.5 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Surface Seal: Yes No Seal Type:
 Depth of Seal bentonite 2' 8' Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 10 feet to 44.5 14.5 bags #3 sand feet

9. WATER LEVEL
 Static water level 22.35 (4/4/92) feet below land surface
 Artesian flow not known G.P.M. P.S.I.
 Water temperature n/k °F Quality n/k

Date started 4/1/92, 19.....
 Date completed 4/2/92, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>NO TEST</u>			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, NV 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date May 15, 1992