WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38806
Permit No.
Basin 089

NOTICE OF INTENT NO. 19991

1. OWNER Groundwater Res. Cons. Inc.
MAILING ADDRESS 1735 E. Ft. Lowell Rd. Ste 4
Tucson, AZ 85719

ADDRESS AT WELL LOCATION Rocky Wayne
24404 Whisky Springs Rd.
Warm Springs (Palomino Valley) NV

2. LOCATION NE ¼ SW ¼ Sec. 7 T. 22 N/S R. 22 E. Washoe County
PERMIT NO. M/O 431-B D-19A (Issued by Water Resources) 77-320-057 (Parcel No.) Palomino Valley (Subdivision Name) Unit 11 7.2.2.

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey gravelly sand				
Grey-brown, dry				
well graded, subangular				
loose, uncemented				
At 4' color change to				
light brown.				
At 11-16' occasional				
boulders				
At 19' slightly moist				
brown				
At 30' mnoderately moist				
At 45' very moist	X	0	85	85
Tuff. Light green				
partially welded				
rhyolite tuff		85	89.2	4.2

Date started 4/24/92, 19
Date completed 4/25/92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 89.2 Feet Depth Cased 89.2 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16 Inches		0 Feet	89.2 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5 PVC		SCH 40	0	89.2
4.5 PVC	End cap	centralizers at 49,88		
4.5 PVC	Locking	cap		

Perforations:
Type perforation factory sawed slot
Size perforation .020 x 3"
From 44.2 feet to 89.2 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal bentonite 2' 38'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No Lonestar
From 40 feet to 89.2 #3 sand feet

9. WATER LEVEL
Static water level 80 (4/25/92) feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature n/k °F Quality n/k

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date June 28, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627