

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 38807
 Permit No. _____
 Basin. 084

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19989

1. OWNER Groundwater Res. Consult. Inc. ADDRESS AT WELL LOCATION Rocketdyne
 MAILING ADDRESS 1735 E. Fort Lowell Rd. Ste 4 2655 Whiskey Springs Rd.
Tucson, AZ 85719 Warm Springs (Palomino Valley) NV

2. LOCATION SW 1/4 SW 1/4 Sec 7 T. 22N N/S R. 22 E Washoe County
 PERMIT NO. M/O-431B D-15A 77-320-01 Palomino Valley Subdivision Name Sub A 4226
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX-190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clayey gravelly sand Grey-brown, dry well graded, subangular loose, uncemented At 13 feet color changes to red-brown, slightly moist		0	24	24
Clayey sandy silt Brown, moderately moist, well graded, subangular, loose uncemented, minor amount of gravel		24	30	6
Clayey gravelly sand Brown, very moist well graded, sub- angular, loose uncemented. At 34 feet cuttings are wet At 38 feet hold produces water	X	30	40	10
Clayey sandy gravel. Brown, well graded, subrounded, loose uncemented.		40	48.7	8.7

8. WELL CONSTRUCTION
 Depth Drilled 48.7 Feet Depth Cased 48.7 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 5/16 Inches To 0 Feet 48.7 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

I.D. Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 40	0	48.7
4" PVC end cap centralizers at 28, 48				
5" PVC locking cap				

Perforations: factory sawed slot
 Type perforation _____
 Size perforation .020 x 3'
 From 28.7 feet to 48.7 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal bentonite 2' 23' Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 25 feet to 48.8 #3 sand feet

Date started 4/6/92, 19_____
 Date completed 4/6/92, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>NO TEST</u>			

9. WATER LEVEL
 Static water level 36.84 (4/7/92) feet below land surface
 Artesian flow NOT KNOWN G.P.M. _____ P.S.I. _____
 Water temperature n/k °F Quality n/k

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
Wayne Drilling, Inc.
 Name _____ Contractor
 Address P.O. Box 12370 Contractor
Reno, NV 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources 908
 Signed Wayne Drilling, Inc. by driller performing actual drilling on site or contractor
 Date June 1, 1992