

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 3881
 Permit No. 084
 Basin. 084

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20121

1. OWNER Groundwater Res. Consultants, Inc. ADDRESS AT WELL LOCATION Rocketdyne
 MAILING ADDRESS 1735 E. Fort Lowell Rd. Ste 4 2655 Whisky Springs Rd.
Tucson, AZ 85719 Warm Springs (Palomino) Valley, NV

2. LOCATION SW 1/4 SW 1/4 Sec. 7 T. 22N N/S R. 22E E Washoe County
 PERMIT NO. M/O 431 D-4A 77-320-01 Palomino Valley Subd 11 4-2-6
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clayey gravelly sand Brown, Well graded angular, loose, un- cemented, fine to coarse grained sand with clay.		0	19	19
Silty sand. Brown moderately graded, loose, uncemented fine sand with silt and clay		19	26	7
Gravelly clayey sand. Brown well graded angular, coarse sand and gravel with some clay. @ 32-34' clay layer @ 40-42" clay layer @ 53' less clay		26	58.8	32.8

8. WELL CONSTRUCTION
 Depth Drilled 58.8 Feet Depth Cased 58.8 Feet

HOLE DIAMETER (BIT SIZE)
 From To
9 5/16 Inches 0 Feet 58.8 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5" PVC		SCH 40	0	58.8
4.5" PVC end cap/centralizers at 23', 58'				
4.5" PVC locking cap				

Perforations: factory sawed slot
 Type perforation.....
 Size perforation..... .020 x 1 1/2 x 6 rows
 From 23.8 feet to 58.8 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 2' bentonite 16' Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No #3 sand
 From 18 feet to 58.8 14 bags feet

Date started..... 09/16/91 19.....
 Date completed..... 09/17/91 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>NO TEST</u>			

9. WATER LEVEL
 Static water level 32.29 (9/22/91) feet below land surface
 Artesian flow not known G.P.M. _____ P.S.I. _____
 Water temperature n/k °F Quality not known

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, NV 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date April 10, 1992