WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38822
Permit No.
Basin 0857

NOTICE OF INTENT NO. 18838

1. OWNER STEFFEN ROBERTSON & KIRSTEN
MAILING ADDRESS 1755 East Plumb Lane, Suite 241
Reno, NV 89502

ADDRESS AT WELL LOCATION Bugsy Bath
2525 So. Virginia Street
Reno, NV

2. LOCATION SE ¼ NW ¼ Sec. 24 T 19N N/S R 19 E Washoe County
PERMIT NO. M/O#397-A RVW-2 (Issued by Water Resources) | Parcel No. | Peppermill area (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other TUBEX 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt concrete		0	½	½
Gravel (fill) predon				
mantly 1 inch dia.				
very well sorted, very				
slightly moist		½		
gravel decresing in				
dia. to ½"			20	19½
Gravelly sand, with				
trace cobbles, brown				
moist.		20	24	4
Sandy gravel, with				
some cobbles, rounded				
to subrounded, brown				
moist.		24	34	10

Date started 12-23-91, 19
Date completed 12-23-91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 34 Feet Depth Cased 34 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16 Inches		0 Feet	34 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5" PVC		sch 40	0	34
4.5" PVC end plug				
4.5" PVC locking cap				

Perforations:
Type perforation factory sawed slot
Size perforation .020 x 1½" x 6 rows
From 19 feet to 34 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 2' bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
11' Ready Mix
Gravel Packed: ☒ Yes ☐ No #6 silica sand
From 17 feet to 34 feet

9. WATER LEVEL
Static water level 25.1 feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature n/k °F Quality n/k

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date June 15, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627