

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19640

1. OWNER Steffen Robertson & Kirsten (U.S.) ADDRESS AT WELL LOCATION Buggy Bath
 MAILING ADDRESS 1755 East Plumb Lane, Suite 241 2525 S. Virginia
Reno, NV 89502 Reno, NV 89509

2. LOCATION SE 1/4 NW 1/4 Sec. 24 T. 19N N/S R. 19 E Washoe County
 PERMIT NO. M/O 397 M-4 Peppermill area Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt to 5". Sand with trace clay, predominantly medium grained, 10% fine and 10% coarse grained subangular light brown, slightly moist,		0	13	13
Gravelly sand, coarse subangular sand, sub-rounded gravel, brown grey,		13	21	8
Gravelly sand, predominantly coarse grained some medium subrounded brownish grey,				
Same lithology to 34'		21	34	12

8. WELL CONSTRUCTION
 Depth Drilled 34 Feet Depth Cased 34 Feet

HOLE DIAMETER (BIT SIZE)
 From To
9 5/16 Inches 0 Feet 34 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5" PVC		SCH 40	0	34
4.5" PVC end cap				
4.5" PVC locking cap				

Perforations:
 Type perforation factory sawed slot
 Size perforation .020 x 1 1/2 x 6 rows
 From 19 feet to 34 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 2'4" bentonite Neat Cement
 Placement Method: Pumped Cement Grout
 Poured 11.6 Concrete Grout

Gravel Packed: Yes No sand
 From 17 feet to 34 med aquarium feet

Date started 03/16/92, 19_____
 Date completed 03/17/92, 19_____
 97 JUN 22 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>NO TEST</u>			

9. WATER LEVEL
 Static water level 25.5 feet below land surface
 Artesian flow not known G.P.M. _____ P.S.I. _____
 Water temperature n/k °F Quality not known

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Address P.O. Box 12370
Reno, NV 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number 908 issued by the Division of Water Resources, the on-site driller
 Signed Aery C. Helman
 By Driller performing actual drilling on site or contractor
 Date April 10, 1992