WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38825
Permit No.
Basin 087

NOTICE OF INTENT NO. 19640

1. OWNER Steffen Robertson & Kirsten (U.S.)
MAILING ADDRESS 1755 East Plumb Lane, Suite 241
Reno, NV 89502

ADDRESS AT WELL LOCATION Buggy Bath
2525 S. Virginia
Reno, NV 89509

2. LOCATION SE ¼ NW ¼ Sec. 24 T 19N N/S R 19 E Washoe County
PERMIT NO. M/O 397 IW-1 (Issued by Water Resources) Parcel No. Peppermill area (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphaltic concrete with aggregate base		0	0.5	0.5
Clayey sand, med. grained, med. dense, brown, moist		0.5	2	1.5
Sand, with minor clay med. grained, sub-angular, med. dense brown, moist		2	12	10
Sand with gravel, fine to coarse grained, subangular to sub-rounded, gray, moist contains abundant subrounded cobbles and boulders		12	20	8
Same: No cobbles and/or boulders below 20		20	22	2
Same: Abundant cobbles and boulders below 22		22	25	3
Same: Saturated below 25, same to 45		25	29	4
Gravelly sand with abundant cobbles, fine to coarse grained predominantly sub-angular sand and sub-rounded gravel, grey		29	45	16

Date started 03/18/92, 19
Date completed 03/19/92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 42 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16 Inches		0 Feet	45 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5" PVC		SCH 40	0	45
4.5" PVC end cap				
4.5" PVC locking cap				

Perforations:
Type perforation factory sawed slot
Size perforation .020 x 1½ x 6 rows
From 17 feet to 44 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 2' bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
11'

Gravel Packed: ☒ Yes ☐ No
From 15 feet to 42 #3 sand feet

9. WATER LEVEL
Static water level 27 feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature n/k °F Quality not known

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed Gary C. Hoffman (By driller performing actual drilling on site or contractor)
Date April 10, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627