

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 38828
 Permit No. 0871
 Basin 0871

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19700

1. OWNER Resna ADDRESS AT WELL LOCATION Unocal Corp.
 MAILING ADDRESS 3164 Gold Camp Drive, Ste 200 1550 Pyramid Way
Rancho Cordova, CA 95670 Sparks, NV
 2. LOCATION NW 1/4 NW 1/4 Sec 4 T 19N N/S R 20 E Washoe County
 PERMIT NO. M/O-314-A MW-3 Sparks Greenbrae & Pyramid Way
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Paving materials		0	0.85	0.85
Silt, trace finegrained sand, mod. yellowish br.		0.85	6	5.15
Silty clay, dark yellowish brown, moderate plasticity		6	7	1
Gravel and cobbles with some silt and fine to medium grained sand		7	9	2
Sand, fine to medium gr. some gravel trace silt		9	10	1
Sandy gravel and cobbles trace silt, fine to med. grained sand, olive gray		10	21	11
Sand, fine to coarse-gr. trace silt and fine gravel, olive gray		21	31	10
Silt, with some fine sand and gravel moderate yellowish brown		31	33.4	2.4

8. WELL CONSTRUCTION
 Depth Drilled 33.4 Feet Depth Cased 31.1 Feet
 HOLE DIAMETER (BIT SIZE)
8 5/8 Inches From To
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		SCH 40	0	33.4
2" PVC		end cap		
2" PVC		locking cap		

Perforations: factory sawed slot
 Type perforation _____
 Size perforation .020 x 1 1/4 x 3 rows
 From 16.5 feet to 31.1 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal bentonite 2' 14' XX Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No w/#2/16 sand
 From 16 feet to 33.4 feet

9. WATER LEVEL
 Static water level 19.1 feet below land surface
 Artesian flow not known G.P.M. _____ P.S.I. _____
 Water temperature n/k °F Quality not known

Date started 3/25/92, 19____
 Date completed 3/25/92, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>NO TEST</u>			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, NV 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 908
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date May 6, 1992