

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 38830  
 Permit No. \_\_\_\_\_  
 Basin 87

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17600

1. OWNER Hydro-Search, Inc. ADDRESS AT WELL LOCATION SEPP Pipeline  
 MAILING ADDRESS 5250 S. Virginia, Ste 280 301 Nugget Ave., Sparks, Nevada  
Reno, NV 89502

2. LOCATION NE 1/4 NW 1/4 Sec 9 T 19N N/S R 20 E Washoe County  
 PERMIT NO. M/6#396 M-9 Tank Farm  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty, sandy clay, gravels, and cobbles (SC-GC) brown, moist silt and fine-coarse sand in brown, plastic clay with subrounded angular gravel and cobbles.</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>Silty sand, gravel and cobbles: (SM-GM) gray-brown, silty, fine-coarse sand and rounded subangular gravel and cobbles</u>		<u>8</u>	<u>32</u>	<u>24</u>
<u>Silty sand, gravel and cobbles (SM-GM) as above, primarily tan-brown.</u>		<u>32</u>	<u>44</u>	<u>12</u>

8. WELL CONSTRUCTION  
 Depth Drilled 44 Feet Depth Cascd 44 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>9 5/16</u> Inches	<u>0</u> Feet <u>44</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

I.D. Size (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6" PVC</u>		<u>Sch 80</u>	<u>0</u>	<u>44</u>
<u>6" PVC</u>	<u>End cap</u>			
<u>6" PVC</u>	<u>Locking cap</u>			

Perforations:  
 Type perforation factory sawed slot  
 Size perforation .064 x 2" x 8 rows  
 From 14 feet to 44 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 2' Bentonite 6'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No #3 sand\*  
 From \*11 to 12' feet to \*12 to 44' feet

9. WATER LEVEL  
 Static water level 24.2 feet below land surface  
 Artesian flow not known G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature n/k °F Quality not known

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc.  
 Address P.O. Box 12370 Contractor  
Reno, NV 89510 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date April 10, 1992

Date started 05/20/91, 19\_\_\_\_\_  
 Date completed same, 19\_\_\_\_\_  
92 JUN 22 11:16

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>NO TEST</u>			