WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38831
Permit No.
Basin 87

NOTICE OF INTENT NO. 17600

1. OWNER Hydro-Search, Inc.
MAILING ADDRESS 5250 S. Virginia, Ste. 280
Reno, NV 89502

ADDRESS AT WELL LOCATION SFPP Pipeline
301 Nugget Ave., Sparks, Nevada

2. LOCATION NE ¼ NW¼ Sec. 9 T 19N N/S R 20 E Washoe County
PERMIT NO. M/O#396 M-10 (Issued by Water Resources) | Parcel No. | Tank Farm (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Other TUBEX 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty sand, gravel and cobbles: (SM-GM) brown-tan, moist silty fine-coarse sand and rounded-angular gravel and cobbles		0	7	7
Gravelly sand (SW) gray-brown, moist, fine-coarse sand and rounded-subangular gravel up to 1" size		7	9	2
Silty sand, gravel and cobbles: (SM-GM) gray-brown, wet, silty fine-coarse sand and rounded-angular gravel and cobbles		9	32	23
Color change to reddish brown		32	44	12

Date started 05/21/91, 19
Date completed same, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST		

8. WELL CONSTRUCTION
Depth Drilled 44 Feet Depth Cased 44 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
9 5/16	0	44

CASING SCHEDULE

Size ~~O.D.~~ I.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6" PVC		sch 80	0	44
6" PVC	end cap			
6" PVC	locking	cap		

Perforations:
Type perforation factory sawed slot
Size perforation .064 x 2" x 8 rows
From 14 feet to 44 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 2' bentonite 3'
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Placement Method: [ ] Pumped [X] Poured
Gravel Packed: [X] Yes [ ] No
#3 sand* coarse aquarium °
From *11 to 12' feet to °12 to 44' feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature n/k °F Quality not known

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] * By driller performing actual drilling on site or contractor
Date April 10, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627