

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17600

1. OWNER Hydro-Search, Inc. ADDRESS AT WELL LOCATION SFPP Pipeline  
 MAILING ADDRESS 5250 S. Virginia, Ste 280 301 Nugget Ave,  
Reno, NV 89502 Sparks, NV

2. LOCATION NE 1/4 NW 1/4 Sec. 9 T. 19N N/S R. 20 E Washoe County  
 PERMIT NO. M/O#396 M-11 Tank Farm  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other/Lubex...190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty sand, clay, gravel and cobbles: (SM-GM)				
Brown, lean clay (probably in thin layers) and moist, brown, silty, fine-coarse sand and rounded angular gravel and cobbles		0	5	5
Silty sand, gravel, cobbles: (SM-GM) all as above, wet, 6-7'				
(color change to gray-brown)		5	18	13
Silty sand, gravel cobbles: (SM-GM) brown, silty, fine-coarse sand and rounded-angular gravel and cobbles		18	44	26

8. WELL CONSTRUCTION  
 Depth Drilled 44 Feet Depth Cased 44 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
9 5/16 Inches 0 Feet 44 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6" PVC		sch 80	0	44
6" PVC end cap				
6" PVC locking cap				

Perforations:  
 Type perforation factory sawed slot  
 Size perforation .064 x 2" x 8 rows  
 From 14 feet to 44 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 2' bentonite 9 1/2'  Neat Cement  
 Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No #3 sand\*  
 From \*12 to 13' feet to 13 to 44' feet

9. WATER LEVEL  
 Static water level 26' feet below land surface  
 Artesian flow not known G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature n/k °F Quality n/k

Date started 05/22/91, 19\_\_\_\_  
 Date completed same, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>NO TEST</u>			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV 89510  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 908  
 Division of Water Resources the on-site driller  
 Signed [Signature]  
 by driller performing actual drilling on site or contractor  
 Date April 10, 1992