WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38850
Permit No.
Basin 091

NOTICE OF INTENT NO. 15387

1. OWNER Hydro-Search, Inc.
MAILING ADDRESS 5259 S. Virginia St. Ste. 280
Reno, Nevada 89502

ADDRESS AT WELL LOCATION Wells Manufacturing
2 Erik Circle
Verdi, Nevada

2. LOCATION SE ¼ SE ¼ Sec 8 T 19N N/S R 18 E Washoe County

PERMIT NO. M/O 363 MW-2A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey gravel, soil 20% clay, dark olive gray		0	2	2
Gravel, coarse, basalt clasts 0-5% clay		2	6	4
Clayey sand, 20% clay, olive brown		6	8	2
Clayey gravel, 20-40% clay, olive brown		8	16	8
Gravel, 10% sand, 5% clay, clasts predominantly basalt		16	29	13

Date started 2.28.91, 19
Date completed 3.1.91, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 29 Feet Depth Cased 29 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16 Inches		0 Feet	29 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		SCH 40	0	29
2" PVC end cap				
2" PVC locking cap				

Perforations:
Type perforation factory sawed slot
Size perforation .020 x 1¼ x 3 rows
From 14 feet to 29 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 1.5 bentonite pellets 9.5 cement w/bentonite and sand
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 11 feet to 29 feet

9. WATER LEVEL
Static water level 18.5' (3/18/92) feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature 49.7 °F Quality not known

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, Nevada 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 31, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627