

OFFICE USE ONLY
 Log No. 38858
 Permit No.
 Basin.....

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Mr. Richard Sewing National Mustang Association Inc. ADDRESS 1st + MAIN Street NEWCASTLE, Utah 84756
 2. LOCATION SE 1/4 SE 1/4 Sec. 6 T. 5 N/S R. 70 E. M.D.B + M Lincoln County
 PERMIT NO. 57428 WALUCY W-2041

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil + SAND		0	70'	70
BROWN CLAY w/ gravel		70	79	9
Fine gravel		79'	82'	3
BROWN CLAY		82'	145	63
Gravel		145	147	2
CLAY		147	150	3
Gravel		150	154	4
CLAY		154	157	3

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 157 feet
 Casing record 2' Above ground to 157
 Weight per foot..... Thickness .250

Diameter	From	To
8 inches	12	157
..... inches

 Surface seal: Yes No Type CEMENT
 Depth of seal 5.5 feet
 Gravel packed: Yes No
 Gravel packed from 5.5 feet to 157 feet
 Perforations:
 Type perforation MILL SLOT
 Size perforation 1/8" x 3"
 From 117 feet to 157 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

9. WATER LEVEL
 Static water level 60 Feet below land surface.....
 Flow..... G.P.M.....
 Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 7-7-92, 1992
 Date completed 7-13, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Name STEVEN Anzalone
 Address STAV Rt Box 21 D NEWCASTLE, UT
 Nevada contractor's license number 0018239
 Nevada driller's license number 811
 Signed Steven Anzalone
 Date July 14/92

BAILER TEST
 G.P.M. 60 Draw down 1 feet 2 hours
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours