

OFFICE USE ONLY
Log No. 38902
Permit No. 59124
Basin 52
1
8997

allied Bldg materials Inc.
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Ernest Selman ADDRESS AT WELL LOCATION Lathrop wells
MAILING ADDRESS _____
2. LOCATION NE 1/4 NE 1/4 Sec 1 T 15 N R 78 E Nye County
PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE Mining
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cinders</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Basalt</u>		<u>10</u>	<u>85</u>	<u>75</u>
<u>Red sand-cinders</u>		<u>85</u>	<u>95</u>	<u>10</u>
<u>Red shale</u>		<u>95</u>	<u>460</u>	<u>365</u>
	<u>X</u>	<u>348</u>		

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 460
12 1/4 Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>.188</u>	<u>71</u>	<u>460</u>

Perforations:
Type perforation Touch
Size perforation 1/4" x 8"
From 320 feet to 460 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 460 feet

RECEIVED
JUL 17 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

9. WATER LEVEL
Static water level 340 feet below land surface
Artesian flow NO 2:00 G.P.M. P.S.I.
Water temperature 60.0 °F Quality OK

Date started 6-2 1992
Date completed 6-30 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>500+</u>		<u>6 hrs.</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Mitchell Enterprise Contractor
Address 630 Betty Contractor
Las Vegas NV 89129
Nevada contractor's license number issued by the State Contractor's Board 27030
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 6475
Signed Robert Mitchell
By driller performing actual drilling on site or contractor
Date 7-6-92