WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38941
Permit No.
Basin 162

NOTICE OF INTENT NO. 11985

1. OWNER Mark Gevet
MAILING ADDRESS
ADDRESS AT WELL LOCATION Newcomb Ave.

2. LOCATION SE ¼ SW ¼ Sec. 35 T. 20S N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) 41-191-08 (Parcel No.) Calvada Valley Lot 15 Unit 3 Blk 34 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	5'	5'
Limestone		5'	7'	2'
Clay		7'	18'	11'
Caliche		18'	20'	2'
Clay		20'	23'	3'
Limestone		23'	31'	8'
Clay		31'	46'	15'
Caliche		46'	48'	2'
Clay		48'	61'	13'
Caliche	WB	61'	63'	2'
Clay		63'	72'	9'
Caliche	WB	72'	74'	2'
Clay		74'	86'	12'
Caliche	WB	86'	88'	2'
Clay		88'	103'	15'
Caliche	WB	103'	105'	2'
Clay		105'	118'	13'
Caliche	WB	118'	120'	2'
Clay		120'	128'	8'
Caliche	WB	128'	130'	2'
Clay		130'	139'	9'
Caliche	WB	139'	140'	1'

Date started 8-24, 1992
Date completed 8-25, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
SEP 1 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0' Feet	140' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
Signed Steve Scease (By driller performing actual drilling on site or contractor)
Date 8-25-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627