

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19418

1. OWNER JOHN DECARLO CONSTRUCTION ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS CARSON CITY, NV 2715 GORDON RD.  
GARDNERVILLE, NV  
 2. LOCATION SW 1/4 N 1/2 1/4 Sec. 34 T. 14 N/S R. 20 E. DOUGLAS County  
 PERMIT NO. Old 21-170-68 NEW APN 1420-37-201-0095 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other NUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	18	18
COARSE SAND		18	24	6
FINE SAND		24	67	43
SANDY CLAY CLAY		67	115	48
CLAY		115	121	6
COARSE SAND	✓	121	124	3
SAND + CLAY LAYERS	✓	124	140	16

'92 MAY -4 P 1:23  
 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 3/8 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation FACTORY SLOT, SINGLE  
 Size perforation 3" X 3/32"  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 27 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC. Contractor  
 Address 7780 CORRY RD  
FALCON, NV 89406 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Paul J. Moore  
 By driller performing actual drilling on site or contractor  
 Date 4-8-92

Date started 4-6, 1992  
 Date completed 4-8, 1992

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>20+</u>	<u>-</u>	<u>1</u>