WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38972
Permit No.
Basin 87

NOTICE OF INTENT NO. 19696

1. OWNER JULIE ETRA/LARRY TURK
MAILING ADDRESS P.O. Box 13196
South Lake Tahoe, CA 95702

ADDRESS AT WELL LOCATION Mt. Rose Hwy.
Reno, NV 89511

2. LOCATION NE ¼ SW ¼ Sec 25 T 18N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 049-051-10 (Parcel No.) Shadow Ridge area. (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Smaller boulder and gravels w/brn clay		1	11	10
Soft brn sandy clay		11	14	3
Smaller boulders and gravels w/brn clay		14	66	52
Vulcanic boulder		66	69	3
Boulders & gravel with brown clay		69	112	43
Brown clay		112	115	3
Soft zone	X	115	126	11
Brown clay		126	130	4
Soft zone	X	130	142	12
Boulders & gravel with brown clay		142	151	9
Volcanci boulder		151	152	1

'92 MAY 8 P12:30
STATE ENGINEER

Date started 4-14-92, 19
Date completed 4-16-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 152 Feet Depth Cased 152 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	152 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	152

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 107 feet to 147 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'(over ¼ mi. from Whites & Thomas Creek)
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 152 feet

9. WATER LEVEL
Static water level 98 feet below land surface
Artesian flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 20, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627