

OFFICE USE ONLY
 Log No. 33973
 Permit No. _____
 Basin. _____
 NOTICE OF INTENT NO. 6059

PRINT OR TYPE ONLY

Please complete this form in its entirety

1. OWNER RON B. MIELZYNSKI ADDRESS AT WELL LOCATION BARONICH off CHARLESTON Hwy. YAKRUMP, NEV 89041
 MAILING ADDRESS 8456 No Oriole (60648) NILES, ILL.
 2. LOCATION SE 1/4 Sec. 23 T. 20 N/S R. 52 E. NYE County
 PERMIT NO. 3 Parcel No. Map 243204 Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	3	3
Gray Clay		3	7	4
White Clay		7	32	25
SANDY WHITE CLAY	x	32	35	3
Caliche		35	37	2
Light Brown Clay		37	95	58
SANDY BROWN CLAY	x	95	100	5
Sticky Brown Clay		100	110	10
Caliche		110	112	2
SANDY GRAY CLAY	x	112	140	28
Gray Clay		140	150	10

8. WELL CONSTRUCTION
 Diameter 12 inches Total depth 150 feet
 _____ inches
 _____ inches
 Casing record 8"
 Weight per foot _____ Thickness 156

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>151</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type CEMENT GROUT
 Depth of seal 55 feet
 Gravel packed: Yes No
 Gravel packed from 55 feet to 150 feet
 Perforations:
 Type perforation Factory Cut
 Size perforation 1 1/2 x 3
 From 110 feet to 130 feet
 From _____ feet to _____ feet

RECEIVED

AUG 21 1990

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 7/30, 1990
 Date completed 8-3, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 40 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Colo. °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Gullard Drilling
 Address 6022 S Encino, LV, NV 89120
 Nevada contractor's license number issued by the State Contractor's Board 4796
 Nevada contractor's driller's number issued by the Division of Water Resources 115
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller _____
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-17-90

BAILER TEST
 G.P.M. 30 Draw down 20 feet 1/2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours