WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 38993
Permit No.
Basin 89

NOTICE OF INTENT NO. 20183

1. OWNER Bob Weise
MAILING ADDRESS 7300 Franktown Road
Carson City, NV 89704

ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ SE ¼ Sec. 22 T. 16 (N)/S R. 19 E. Washoe County
PERMIT NO. M/O-531 (Issued by Water Resources) | Parcel No. | Lightning W RAnch (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. (21) LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| GRAY CLAYEY SAND (SC) | | 0.0 | 2.0 | 2.0 |
| BROWN -GRAY CLAYEY SAND (SC) | yes | 2.0 | 3.5 | 1.5 |
| BROWN CLAYEY SAND (SC) | yes | 3.5 | 15.0 | 11.5 |

RECEIVED '92 JUN 10 P1:52 STATE ENGINEERS OFFICE

Date started 4/9, 19 92
Date completed 4/9, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 15.0 Feet Depth Cased 15.0 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8.0 Inches | 0.0 Feet | 15.0 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.0 | 0.5 | Schedule 40 | 0.0 | 15.0 |
| | | | | |

Perforations:
Type perforation Slot
Size perforation .02
From 2.5 feet to 15.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0.5
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 2.5 feet to 15.0 feet

9. WATER LEVEL
Static water level 3.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Mark E. DeBusk (Contractor)
Address 520 Edison Way (Contractor)
Reno, NV 89502
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1768
Signed Mark E. DeBusk (By driller performing actual drilling on site or contractor)
Date 5/11/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627