

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 8169

1. OWNER Double JA Lan & Livestock, Inc. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS c/o John Ascuaga
Ascuaga's Nugget, P.O. 797, Sparks, NV 89432
 2. LOCATION SE 1/4 SE 1/4 Sec. 24 T. 11 N. R. 23 E. Lyon County
 PERMIT NO. 49446 & 49447 Issued by Water Resources Parcel No. _____ Subdivision Name _____
558 55841

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & sand		0	40	40
Rock & sand		40	90	50
Sandy clay		90	110	20
Rock, sand & clay		110	130	20
Coarse sand & clay		130	160	30
Clay, sand & rocks		160	180	20
Clay & gravel		180	200	20
Rocks & clay		200	220	20
Clay, sand & gravel		220	240	20
Coarse sand		240	260	20
Clay & gravel		260	270	10
Sandy gravel		270	320	50
Clay & sand		320	340	20
Clay, sand & gravel		340	360	20
Gravel w/ clay stringers		360	400	40
Sandy clay, gravel		400	460	60
Clay & gravel		460	500	40
Sand, gravel & clay		500	610	110
Gravel & clay		610	750	140
Sand		750	760	10

8. WELL CONSTRUCTION
 Diameter 24 inches Total depth 760 feet
30 inches to ~~128~~ 128'
 Casing record .375 to 128'
 Weight per foot _____ Thickness .250
 Diameter From To
26 inches +1 feet 128 feet
~~16~~ inches +1 feet 760 feet
 _____ inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 128' feet
 Gravel packed: Yes No
 Gravel packed from 128 feet to 760 feet
 Perforations:
 Type perforation Saw cut
 Size perforation 1/8 x 2 1/2
 From 240 feet to 760 feet
 From _____ feet to _____ feet

Date started April 3, 1992
 Date completed April 20, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 22 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMPSON DRILLING CO., INC.
4185 W. Harmon Contractor
Las Vegas, NV 89103 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 4286A
 Nevada contractor's driller's number issued by the Division of Water Resources 290
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 675
 Signed Richard R. Thompson
 By driller performing actual drilling on site or contractor
 Date June 2, 1992