WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39155
Permit No.
Basin 8-102 CHURCHILL V.

NOTICE OF INTENT NO.

1. OWNER Joe Bertles
MAILING ADDRESS P.O. Box 203 Silver Springs NV. 89429
ADDRESS AT WELL LOCATION 3165 Hollyhawk Lane Silver Spring NV. 89429

2. LOCATION NE ¼ NW ¼ Sec. 25 T. 18 N/S R. 24 E. LYON County
PERMIT NO. NA (Issued by Water Resources) 15-171-07 (Parcel No.) Powell Ranch Estates (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel	✓	117	127	10
Brown clay		127	170	47
Course Sand	✓	170	176	6
Brown clay		176	183	7
Small Gravel	✓	183	191	8
Brown clay		191	211	20
Small Gravel	✓	211	223	12
Brown clay		223	235	12
Gravel	✓	235	238	3

Date started 4/10, 19 92
Date completed 4/15, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	235'	3½

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	Inches	From (Feet)	To (Feet)
	8"	117	238'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	188	+1	238'

Perforations:
Type perforation Torch Cut
Size perforation 1/8 x 6 = 4 Rows
From ____ feet to ____ feet
From 108' feet to 128' feet
From ____ feet to ____ feet
From 175' feet to 238 feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow NA G.P.M. ____ P.S.I.
Water temperature Cold °F Quality good - clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address P.O. Box 599 Silver Springs NV. 89429 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5/9/92

MAY 15 AM 10:47 '92 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627