

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Seth Bidegary ADDRESS AT WELL LOCATION  
 MAILING ADDRESS P.O. Box 63 150 2nd West St.  
Paradise Valley, Nv. 89426 Paradise Valley, Nevada

2. LOCATION N 1/2 1/4 NW 1/4 Sec. 25 T. 42 N/S R. 39 E. Humboldt County  
 PERMIT NO. 04-391-21 Bidegary Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Sandy Clay		5	10	5
Clay		10	18	8
Sand / Pea Gravel		18	28	10
Gravel/Sand/10% Clay		28	40	12
Fine Sand		40	50	10
Sand and Gravel		50	55	5
Gravel/20% Clay		55	68	13
Sandy Clay		68	82	14
Sand and Decomposed Gr				
Granite / Silt		82	140	58

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
<u>10</u>	<u>0</u>	<u>140</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>80</u>
<u>"</u>	<u>"</u>	<u>"</u>	<u>100</u>	<u>120</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 1/8 X 2

From	feet to	From	feet to
<u>80</u>	<u>100</u>	<u>140</u>	
<u>100</u>	<u>140</u>		

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 18 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling and Pump Co. Contractor  
 Address P.O. Box 590 Contractor  
Winnemucca, Nevada 89446-0590  
 Nevada contractor's license number 015234 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713  
 Signed C. P. Epler  
 By driller performing actual drilling on site or contractor  
 Date 5-5-92

Date started April 30, 1992, 1992  
 Date completed May 1, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>Air on Rig</u>	<u>4 hrs.</u>

92 MAY -7 P 1:05  
 RECEIVED  
 STATE ENGINEERS CLINIC