

OFFICE USE ONLY  
 Log No. 39209  
 Permit No. T  
 Basin 87  
 NOTICE OF INTENT NO. 19661

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Robert Fagot  
 MAILING ADDRESS P. O. Box 12340  
 Reno, Nv 89510  
 ADDRESS AT WELL LOCATION 5300 Castlepeak Rd  
 Lot 535  
 2. LOCATION SW 1/4 SE 1/4 Sec 20 T 18 N/S R 21 E Storey County  
 PERMIT NO. 04-221-61 - Virginia City Highlands  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Multi-colored volcanic rock & sands		0	60	60
Multi-colored volcanic rock		60	197	137
Green volcanic rock with red & black spots & streaks	X	197	220	23
Green red streaks green black spot little red & black		220	238	18
T.D. 238 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 238 Feet  
 Depth Cased 238 Feet  
 HOLE DIAMETER (BIT SIZE)  
 10 5/8 Inches From 0 Feet To 60 Feet  
 8 1/2 Inches From 60 Feet To 238 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.72	.188	+ 1	238

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 208 feet to 228 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 238 feet

9. WATER LEVEL  
 Static water level 155 feet below land surface  
 Artesian flow G.P.M. P.S.I.  
 Water temperature cold °F Quality

Date started 5/6/92, 19  
 Date completed 5/7/92, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	20+		1

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L  
 Sparks, Nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1804  
 Division of Water Resources, the on-site driller  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 5/8/92