

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19737

1. OWNER JOHN & MECHELE RAGSDALE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 55 Lonesome Polecat 8045 List Country Rd
Carson City, NV 89704 Carson City, NV 89704
 2. LOCATION NE 1/4 NE 1/4 Sec. 35 T. 16 N/S R. 19 E Washoe County _____
 PERMIT NO. 55-240-08 None
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	4	4
Firm DG		4	90	86
Fractured DG carrying small qty of water, 1 to 2 gpm	xx	90	115	25
Firm, hard DG		115	165	50
Fractured DG with water		165	180	15
TD: 180 feet				
Well capacity: 40 plus gpm				

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 60 Feet
11 1/2 Inches 9 1/2 Inches
 60 Feet 180 Feet
 Casing Schedule

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.1	.188	0	180

Perforations:
 Type perforation Factory Mill Slotted
 Size perforation 37/32" x 3"
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 60'
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 60 feet to 180 feet

9. WATER LEVEL
 Static water level 15' feet below land surface
 Artesian flow 40 plus G.P.M. P.S.I.
 Water temperature _____ °F Quality _____

Date started May 15, 1992
 Date completed May 18, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Blowing	<u>40 plus gpm</u>	<u>from 140</u>	<u>for 2 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO. Contractor
 Address 5551 Hiway 50 E #3
Carson City, NV 89701
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
 Signed Joe Butts
 By driller performing actual drilling on site or contractor
 Date 5-20-92

92 MAY 20 AM 152
 RECEIVED
 STATE ENGINEERS OFFICE