WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39212
Permit No.
Basin 89

NOTICE OF INTENT NO. 19807

1. OWNER JOHN KING
MAILING ADDRESS P.O. BOX 6731
Reno, NV 89513

ADDRESS AT WELL LOCATION
900 Brenda Way
Carson City, NV 89704

2. LOCATION NW ¼ NE ¼ Sec 30 T 17N N/S R 20 E Washoe County
PERMIT NO. (Issued by Water Resources) 050-253-08 (Parcel No.) New Washoe City (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Loose DG		1	9	8
Brown clay with DG mix		9	36	27
Rusty clay with DG mix		36	66	30
Weathered granite		66	89	23
Soft zone(NO WATER)		89	90	1
Weathered granite		90	115	25
Soft zone(app 3 GPM)	X	115	116	1
Weathered granite		116	156	40
~~Weathered granite~~		~~156~~	~~183~~	~~27~~
Soft zone		156	183	27
Weathered granite		183	212	29
Soft zone	X	212	215	3
WEathered granite		215	225	10

'92 JUN -4 AM 10 51
STATE ENGINEER

Date started 5-26-92, 19
Date completed 5-27-92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	225 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	225

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 160 feet to 180 feet
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 225 feet

9. WATER LEVEL
Static water level 64 feet below land surface
Artesian flow 15 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Edward F. Fronchoya
By driller performing actual drilling on site or contractor
Date May 28, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627