WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39220
Permit No.
Basin 92A

NOTICE OF INTENT NO. 19688

1. OWNER JIM & ANNETTE FOSS
MAILING ADDRESS P.O. Box 50063, Reno, NV 89513
ADDRESS AT WELL LOCATION 10890 Plata Mesa, Reno, NV 89506

2. LOCATION NE ¼ NE ¼ Sec 25 T 21N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 86-192-05 Subdivision Name Silver Knolls

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	38	38
Soft zone		38	42	4
Brown clay		42	68	26
Soft zone	X	68	72	4
Brown clay		72	111	39
Brown coarse sand	X	111	122	11
Brown clay		122	123	1
Soft sandy clay		123	128	5

Date started 5-6-92, 19
Date completed 5-6-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 128 Feet Depth Cased 128 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	128 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	128

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 101 feet to 121 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 128 feet

9. WATER LEVEL
Static water level 44 feet below land surface
Artesian flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date May 7, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627