WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39293
Permit No.
Basin 84

NOTICE OF INTENT NO. 21504

1. OWNER Joseph Lopiccolo/Kathrene Predal
MAILING ADDRESS 423 Smithridge
Reno, NV 89502

ADDRESS AT WELL LOCATION 3855 Right Canyon Road
Reno, NV 89510

2. LOCATION NE ¼ SW ¼ Sec. 28 T. 22N N/S R. 22 E. Washoe County
PERMIT NO. (Issued by Water Resources) 077-290-02 (Parcel No.) Palomino Valley Unit 11 28-2-2-4 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Weathered granite		1	3	2
Green granite		3	47	44
Soft zone		47	49	2
Green granite		49	83	34
Gray granite		83	91	8
Green granite		91	261	170
Gray granite		261	290	29
Fracture	X	290	291	1
Gray granite		291	315	24
Fracture	X	315	316	1
Gray granite		316	325	9

Date started 6-1-92, 19
Date completed 6-3-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 325 Feet Depth Cased 325 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	325 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	325

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 280 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 325 feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow 25 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date June 11, 1992

JUL 15 1992 STATE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627