WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39340
Permit No.
Basin 102

NOTICE OF INTENT NO. 19119

1. OWNER Al Baupre
MAILING ADDRESS 2730 E. Antalope St.
Silver Springs Nevada

ADDRESS AT WELL LOCATION 2730 East Antalope St.
Silver Springs Nevada

2. LOCATION SE ¼ NE ¼ Sec. 20 T. 17 X N/S R. 25 E. Lyon County
PERMIT NO. - (Issued by Water Resources) 17-472-13 (Parcel No.) - lot 125 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Loose Sand | | 0 | 10 | 10 |
| Sandy Clay | | 10 | 60 | 50 |
| Sandstone | | 60 | 65 | 5 |
| Sand with thin Streaks | | | | |
| of clay Some small | | | | |
| Gravel in sand | | 65 | 160 | 95 |

'92 JUN 24 A10:29 STATE ENGINEER'S OFFICE

Date started June 16, 1992
Date completed June 18, 1992

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 100 | air on rig | 5 hrs. |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 10 | 0 | 160 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | +2 | 60 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill
Size perforation 1/8 X 2
From 60 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow - G.P.M. - P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling and Pump Co. (Contractor)
Address P.O.Box 590 (Contractor)
Winnemucca, Nevada 89446-0590

Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources to the on-site driller 1195
Signed C. C. Epler (By driller performing actual drilling on site or contractor)
Date 6/23/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (01-627)