

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF PERMIT NO. 15557

1. OWNER WASHOE Co. UTILITIES ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 11130
RENO, NEV 89520
 2. LOCATION SE 1/4 NW 1/4 Sec 22 T 18 N R 20 E County _____
 PERMIT NO. M10-585 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>STIFF, BRN, SILTY CLAY & SANDY CLAY</u>		<u>0</u>	<u>25</u>	<u>25</u>
<u>HARD, BROWN GRAVELLY CLAY</u>		<u>25</u>	<u>34</u>	<u>9</u>
<u>COMPACT, BRN, CLAYEY SAND & VERY FINE SAND</u>		<u>34</u>	<u>55</u>	<u>21</u>

NOTE: BENTONITE PLUG FROM 23° - 25° FT. & CONCRETE GROUT FROM SURFACE TO 23° FT.

8. WELL CONSTRUCTION
 Depth Drilled 55 Feet Depth Cased 55 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 55 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 3/8</u>		<u>SCH 40</u>	<u>0</u>	<u>55</u>
		<u>PYC</u>		

Perforations:
 Type perforation FACTORY CONTINUOUS SLOT
 Size perforation # 40 SLOT
 From 30 feet to 50 feet
 _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 2.5
 Placement Method: Pumped Poured
 Gravel Packed: Yes No #3 SAND
 From 25 feet to 54 feet

9. WATER LEVEL
 Static water level 28 1/2 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality NOT TESTED

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started OCT 2 1992
 Date completed OCT 3 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>BAILING BY HAND WITH 5' BAILER EVACUATES THE CASING. RECOVERY IS MODERATELY SLOW</u>		

Name _____ Contractor _____
 Address _____ Contractor _____
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1621
 Signed Tom Cordova
 By driller performing actual drilling on site or contractor
 Date OCT 5, 1992