WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39393
Permit No.
Basin 89

NOTICE OF INTENT NO. 21402

1. OWNER: JOHN BROWN
MAILING ADDRESS: 1052 Roberts Street, Reno, NV 89502
ADDRESS AT WELL LOCATION: 1110 Skinner, Carson City, NV 89704

2. LOCATION: NW ¼ NW ¼ Sec. 30 T. 17N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) | 50-251-06 (Parcel No.) | Washoe Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown sandy clay		2	18	16
Rusty brown dg		18	35	17
Weathered granite		35	118	83
Soft zone(app 1½GPM)	X	118	124	6
Weathered granite		124	166	42
White granite		166	180	14
Soft zone	X	180	198	18
Hard white granite		198	206	8

UTM E 0255822
N 4355428
NAD 27
RC
8-21-06

Date started 10-9-92, 19
Date completed 10-9-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 206 Feet Depth Cased 206 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	206 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	206

Perforations:
Type perforation: factory sawed slot
Size perforation: 3/32 x 3 x 5 around
From 159 feet to 199 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 206 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow 15 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date October 10, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627