WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39394
Permit No.
Basin 90 LAKE TAHOE

NOTICE OF INTENT NO. 10538

1. OWNER U.S. FOREST SERVICE
MAILING ADDRESS 870 EMERALD RD. SO. LAKE TAHOE, CA. 96150
ADDRESS AT WELL LOCATION ZEPHYR COVE RESORT

2. LOCATION SE ¼ NW ¼ Sec. 10 T. 13 N/S R. 18 E. DOUGLAS County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & SAND		0	10	10
GRANITE CLAY MIX		10	25	15
WHITE GRANITE		25	30	5
WEATHERED GRANITE				
MAKING LOTS OF WATER		30	105	75
GRANITE		105	115	10
GRANITE SANDY CLAY		115	117	2
HARD GRAY CLAY		117	119	2
GRANITE WHITE BLACK				
SOME BROWN CHIPS		119	120	1
GRANITE GRAY CLAY		120	135	15
WHITE BLACK GRANITE		135	165	30
BLOWING OUT RIVER				
ROCK, Sands and				
GRAVEL at 85'				

Date started 10/13, 1992
Date completed 10/16, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 83 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 1/2 Inches	0 Feet	165 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	—	SCH 40	+2	83

Perforations:
Type perforation SLOTTED
Size perforation .020
From +2 feet to 78 feet Blank
From 78 feet to 83 feet PERF
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 75 feet to 83 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT DRILLING, INC. Contractor
Address 9955 NORTH VIRGINIA ST. Contractor
RENO, NEVADA 89506
Nevada contractor's license number issued by the State Contractor's Board 0026917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593
Signed Dan Brown
By driller performing actual drilling on site or contractor
Date 10/27/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

STATE ENGINEER 92 OCT 29 PM 3:06