WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39395
Permit No.
Basin 90 LAKE TAHOE

NOTICE OF INTENT NO. 10537

1. OWNER U.S. FOREST SERVICE
MAILING ADDRESS 870 EMERALD RD.
SO. LAKE TAHOE, CA 96150
ADDRESS AT WELL LOCATION ZEPHYR COVE RESORT

2. LOCATION SW ¼ NE ¼ Sec. 10 T. 13 N/S R. 18 E. DOUGLAS County

PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTS		0	10	10
GRANITE		10	30	20
GRANITE & FLOWING SAND		30	55	25
FLOWING SAND W/ White Granite		55	60	5
WHITE & BLACK GRANITE		60	160	100
WATER HAD GREEN TINT		110	150	40
WATER HAD BLACK TINT		150	160	10
ABANDON WELL TO FULL DEPTH WITH NEAT CEMENT				

'92 OCT 29 P4:06 STATE ENGINEER

Date started 10/8, 19 92
Date completed 10/13, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 1/2 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 1' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT DRILLING, INC. Contractor
Address 9955 NORTH VIRGINA ST Contractor
RENO, NEVADA 89506
Nevada contractor's license number issued by the State Contractor's Board 0026917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593
Signed Dan Granger
By driller performing actual drilling on site or contractor
Date 10/27/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627