WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39405
Permit No.
Basin 101

NOTICE OF INTENT NO. 21415

1. OWNER Tiffany Stone
MAILING ADDRESS 6766 Reno Hwy
Fallon, NV 89406

ADDRESS AT WELL LOCATION
1933 Western Avenue
Fallon, NV 89406

2. LOCATION NW ¼ NE ¼ Sec. 19 T. 19 N/S R. 28 E Churchill County
PERMIT NO. (Issued by Water Resources) | 008-132-25 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	7	7
Fine Green Sand		7	12	5
Brown Clay		12	19	7
Brown Coarse Sand		19	24	5
Brown Clay		24	28	4
Fine Brown Sand		28	38	10
Fine Green Sand		38	41	3
Black & Green Coarse Sand		41	47	6
Brown Clay		47	49	2
Brown COarse Sand	X	49	54	5

'92 OCT 16 P1:08 STATE ENGINEER

Date started October 7, 19 92
Date completed October 7, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 54 Feet Depth Cased 54 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	54 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	54

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 50 feet to 53 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 45
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 45 feet to 54 feet

9. WATER LEVEL
Static water level 12' 3" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Oct 8, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627