WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39408
Permit No.
Basin 101

NOTICE OF INTENT NO. 20544

1. OWNER H R H PRoperties
MAILING ADDRESS 710 W Williams
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4046 Cimmaron Road
Fallon, NV 89406

2. LOCATION NE ¼ NE ¼ Sec. 33 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) 08-691-89 (Parcel No.) Pheasant Green (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	8	8
BROWN COARSE SAND		8	12	4
BROWN CLAY		12	16	4
BROWN COARSE SAND		16	27	11
FINE BROWN SAND		27	31	4
BROWN COARSE SAND		31	41	10
GREEN FINESAND		41	43	2
BLACK & GREEN COARSE SAND		43	47	4
BLACK SILT		47	53	6
BLACK & GREEN COARSE SAND		53	58	5
BROWN CLAY		58	61	3
BROWN COARSE SAND	X	61	82	21

'92 OCT 16 P1:08 STATE ENGINEER

Date started OCTOBER 5, 19 92
Date completed OCTOBER 5, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 82 Feet Depth Cased 82 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	82 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	82

Perforations:
Type perforation Millent
Size perforation 1/8"
From 78 feet to 81 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 70
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 70 feet to 78 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 FALLON, NV 89407 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date 10-6-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627