

OFFICE USE ONLY
 Log No. 39427
 Permit No. 105
 Basin 105

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 18940

1. OWNER Rich Aitkenhead ADDRESS AT WELL LOCATION 1781 Rittercrest
 MAILING ADDRESS PO BOX 369 GARD. NV 89410
 2. LOCATION NE 1/4 SW 1/4 Sec. 36 T. 13 N/S R. 20 E Douglas County
 PERMIT NO. 23-473-50 Parcel No. Wickliffe Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & SAND		0	10	
SAND		10	35	
SAND & GRAVEL		35	45	
SAND		45	70	
GRAVEL SAND & ROCKS		70	105	
GRAVEL & SAND		105	115	
SAND		115	135	
GRAVEL CLAY & SANDS		135	150	
SAND		150	170	
CLAY & SAND		170	230	

92 OCT -B A19 09
 STATE ENGINEERS

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 230 feet
 Casing record
 Weight per foot Thickness 18P
 Diameter From To
6 inches 0 feet 230 feet
 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 230 feet to 50 feet
 Perforations:
 Type perforation Factory Perf
 Size perforation 3" X 5/8"
 From 230 feet to 210 feet

9. WATER LEVEL
 Static water level 84 feet below land surface
 Flow G.P.M. P.S.I.
 Water temperature °F Quality

Date started 8-25 19 92
 Date completed 8-28 19 92

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>1400</u>	<u>40+</u>		<u>2hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kochspek Drilling Inc. Contractor
 Address 2668 Fuller Minion Contractor
 Nevada contractor's license number issued by the State Contractor's Board #021268
 Nevada contractor's driller's number issued by the Division of Water Resources #1300
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #455
 Signed Michael Allen
 By driller performing actual drilling on site or contractor
 Date 8-29-92

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours