

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22207

1. OWNER Loewen Area ADDRESS AT WELL LOCATION 1352 Scenic
 MAILING ADDRESS PO Box 1664 minden NV 89423
 2. LOCATION N 1/2 S 2 E 28 T 14 N S R 20 Douglas County
 PERMIT NO. 21-061-11 Parcel No. _____ Subdivision Name Johnson 7w
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	30	
CLAY & SAND		30	35	
GRAVEL CLAY & SAND		35	40	
SAND		40	45	
GRAVEL & CLAY		45	55	
SAND	X	55	65	
GRAVEL & CLAY		65	75	
SAND & CLAY		75	90	
CLAYS		90	105	
SAND & CLAY	X	105	140	

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.5</u>	<u>.188</u>	<u>0</u>	<u>140</u>

At the same location
 BY WAY OF ABOUT PUMP & NEAT CEMENT
 the existing 4" well of an appx.
 60' depth was given an abandonment
 plug seal

Perforations:
 Type perforation Factory Feet
 Size perforation 3" x 5/16"
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

1926 OCT -8 AM 10:09
 STATE ENGINEERS OFFICE

9. WATER LEVEL
 Static water level 23 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 Quality _____

Date started 9-24, 1992
 Date completed 9-26, 1992

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name Frederick Drilling Inc Contractor
 Address 268 Keller Minden NV 89423 Contractor
 Nevada contractor's license number #021268 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 4495
 Signed Mechael Colton
 By driller performing actual drilling on site or contractor
 Date 10-6-92

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AKK</u>	<u>30+</u>	<u>-</u>	<u>2 hrs</u>