WHITE–DIVISION OF WATER RESOURCES
CANARY–CLIENT'S COPY
PINK–WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39507
Permit No.
Basin 102

NOTICE OF INTENT NO. 19361

1. OWNER William Lee BeHS
MAILING ADDRESS 7994 Springfield
Silver Springs Nev 89429

ADDRESS AT WELL LOCATION 3340 E. Badger
Silver Springs Nev 89429

2. LOCATION NE ¼ SW ¼ Sec. 21 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 17-482-11 (Parcel No.) Lot 158 Stockton Sub #3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard Pan		0	1	1
Fine Sand		1	4	3
Brown Clay & Sand		4	38	34
Coarse Sand & Gravel		38	47	9
Hard Brown Clay		47	125	78
Bluish Gray Clay		125	135	10
Bluish Gray Fine to Coarse Sand		135	158	23
Brown Clay		158	174	16
Brown Clay & Sand		174	186	12
Brown Clay		186	201	15
Coarse Sand & Small Gravel	X	201	231'3"	*30'3"

RECEIVED 92 SEP -3 AM 10:58 STATE ENGINEERS OFFICE

Date started 6-10, 1992
Date completed 6-12, 1992

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	28	10	½ Hrs

8. WELL CONSTRUCTION
Depth Drilled 231 Feet Depth Cased 232'3" Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
11	0	231'3"

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	231'3"

Perforations:
Type perforation Sawed
Size perforation 1/8 x 3" x 6 Rows
From 211 feet to 231'3" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 20 feet to 231'3" feet

9. WATER LEVEL
Static water level 40' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ocden Bros Drilling (Contractor)
Address 162 N. By Bee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-7-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627